

कार्यालय अधिशासी अभियन्ता खण्ड कार्यालय, उ०प्र० जल निगम (ग्रामीण), गाजियाबाद।

पत्रांक ३५४ / स्पा-३ / १८ दिनांक:- १७/०५/२०२५
सेवा में,

Chairman,
Inspire International School,
Sector-10, Village-Vaidpura,
Greater Noida West,
Gautam Budh Nagar.

विषय:- ग्राम वैदपुरा, गौतमबुद्धनगर में स्थित स्कूल के पीने के पानी के नमूने की जाँच के सम्बन्ध में।

महोदय,

उपरोक्त विषयक, आपके पत्र संख्या शून्य दिनांक ११.०४.२०२५ के द्वारा १ नग ग्राम वैदपुरा, गौतमबुद्धनगर में स्थित Inspire International School के पीने के पानी का नमूना आपके द्वारा अपने स्तर से एकत्र कर जाँच करने हेतु जनपदीय प्रयोगशाला गाजियाबाद में जमा कराया गया था।

उक्त जल नमूने की जाँच जनपदीय प्रयोगशाला गाजियाबाद में कर ली गयी है, जाँच रिपोर्ट संलग्न कर प्रेषित की जा रही है। जल की जाँच आपके द्वारा उपलब्ध कराये गये जल नमूने के आधार पर की गयी है। यह जाँच कानूनी प्रकरणों हेतु मान्य नहीं है।

संलग्नक:- उपरोक्तानुसार।

भवदीय



(महेन्द्र कुमार)

सहायक अभियंता

पृ०सं० एवं दिनांक उपरोक्तानुसार:-

प्रतिलिपि:- निम्नलिखित को सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित।

१. अधिशासी अभियंता महोदय, खण्ड कार्यालय, उ०प्र० जल निगम (ग्रामीण), गाजियाबाद।
२. जूनियर इंजिनियर (लैब), जनपदीय प्रयोगशाला, गाजियाबाद।
३. कुमारी अंजली पौरवाल (लैब कैमिस्ट), जनपदीय प्रयोगशाला, गाजियाबाद।

PRINCIPAL

INSPIRE INTERNATIONAL SCHOOL
VAIDPURA, SEC-10, GR. NOIDA WEST

G. LATTER

CHAIRMAN

INSPIRE INTERNATIONAL SCHOOL
VAIDPURA, SEC-10, GR.

सहायक अभियंता



TEST REPORT

District Level Water Analysis Laboratory, U.P. Jal Nigam(Rural)
Ghaziabad



TC-12972

Report No. C/04/25-11995

Issue Date: 16/04/2025

Customer Details

Office Name and Address of the Inspire International School, G.B. Nagar -203207
Ref. Letter No ; Date 11/04/2025

Basic details of sample

District	G.B Nagar	Block-	-
Habitation	-	Location	Baidpura Sec.-10
Gram Panchayat	-	Village-	-
Water Source	RO Water		
Quantity of Sample	1000 ml	Sample No.-	1
Receiving Date	11.04.2025	Date of Sample Collection -	11.04.2025
Sample Depositer	Mr. Harish Nagar	Sample Collector	Mr. Harish Nagar
Analysis Start Date	15-04-2025	Analysis Completion Date	15-04-2025

Environmental Condition

Temperature: 25±2°C

Relative Humidity 50± 15%

Technical Data of Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per IS		Reference Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	PH(27.1°C)	-	6.96	6.5-8.5	6.5-8.5	IS 3025 (Part 11)Electrometric:2022
2	Turbidity	NTU	0.42	1.00	5.00	IS 3025 (Pt 10):2023
3	TDS	mg/L	92.37	500	2000	IS 3025 (Pt 16):2023
4	Chloride	mg/L	24	250	1000	IS 3025 (Part32)Argentometric:2019
5	Total Alkalinity	mg/L	76	200	600	IS 3025 (Part 23):2023
6	Total Hardness	mg/L	48	200	600	IS 3025 (Part 21):2019
7	Sulphate	mg/L	4.8	200	400	APHA 24th Edition -4500-SO4 Method E (Turbidimetric Method): 2023
8	Nitrate	mg/L	1.36	45	45	APHA 24th Edition -4500- NO3 Method B (UV Screening Method): 2023
9	Calcium as Ca	mg/L	9.6	75	200	IS 3025 (Part 40): 2023
10	Magnesium as Mg	mg/L	5.76	30	100	IS 3025 (Part 46): 2023
11	Odour	Qualitative	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
12	Color	CU	2	5	15	IS 3025 (Part 4): 2021
13	Iron	mg/L	BDL	0.1-1.0	0.1-1.0	APHA 24th Edition -3500-Fe Method B (Phenanthroline Method) : 2017
14	Fluoride	mg/L	0.076	1.0-1.5	1.0-1.5	APHA 24th Edition -4500-F Method C (Electrode Method) : 2023

NOTE

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days from the date of issue of tests reports unless otherwise specified.
5. BDL Means Below Detaction Limit (Iron Lower Limit is 0.1)

Prepared By

PRINCIPAL

INSPIRE INTERNATIONAL SCHOOL
Baidpura, Sec-10, GR. NOIDA WEST

Tested By

Authorised Signatory

Anjali Porwal
(Chemist & Quality /Technical Manager)
District level Water Analysis Laboratory Ghaziabad

CHAIRMAN

INSPIRE INTERNATIONAL SCHOOL

End of The Report

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Ms. Anjali Porwal (Chemist) & Gansol (A)

(Name of Officers with designation) from Dist. Lab Ghaziabad PHED

inspected the Inspire International School, Sec-10, Vaidpura, G.B. Nagar

(Name & Address of the school) on 10.04.2015 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. C/04/25-11995 dated 16.04.2015

of U.P. Jal Nigam (Gramin) Lab (PHED Lab) certified that the

Inspire International School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 16.04.2016

Signature with Seal:

Name

Designation

Name & Address of the Office / Department:

Assistant Engineer


Division Office

U.P. Jal Nigam (Gramin)

Ghaziabad


To Inspire International School
Sec-10, Vaidpura, G.B. Nagar
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



PRINCIPAL

INSPIRE INTERNATIONAL SCHOOL
VAIDPURA, SEC-10, GR. NOIDA WEST



CHAIRMAN

INSPIRE INTERNATIONAL SCHOOL
VAIDPURA, SEC-10, GR. NOIDA WEST